



NOTES:

1. TRENCH SHALL BE BACKFILLED AND COMPACTED IN ACCORDANCE WITH WSDOT 7-08.3(3) OR AS APPROVED IN WRITING BY THE CITY ENGINEER.
2. PIPE ZONE BEDDING SHALL BE GRAVEL BACKFILL FOR PIPE ZONE BEDDING IN ACCORDANCE WITH WSDOT 9-03.12(3) OR AS APPROVED IN WRITING BY THE CITY ENGINEER.
3. FOR EXISTING ROADS, BACKFILL MATERIAL ABOVE THE PIPE ZONE SHALL BE 1 1/4" CRUSHED ROCK. FOR NEW ROAD CONSTRUCTION, BACKFILL MATERIAL ABOVE THE PIPE ZONE SHALL BE GRAVEL BORROW OR SELECT BORROW IN ACCORDANCE WITH WSDOT 9-03.14 OR 1 1/4" CRUSHED ROCK OR AS APPROVED IN WRITING BY THE CITY ENGINEER.

Approved: *[Signature]* March 16, 2018
 City Engineer Date
STORM DRAIN STANDARD DETAIL



Dwg No: **SD1**
TYPICAL STORM DRAIN PIPE TRENCH SECTION