



NOTE:
CHECK VALVE REQUIRED BETWEEN PUMP AND BALL VALVE

Approved: *[Signature]* March 16, 2018
 City Engineer Date
SANITARY SEWER STANDARD DETAIL



Dwg No: **SS13**
**SMALL DIAMETER
 FORCE MAIN CONNECTION**