



- NOTES:**
1. LIFT STATION SITE LAYOUT SHOWN IS THE MINIMUM REQUIREMENT PER THE CITY OF BONNEY LAKE. ACTUAL LAYOUT MAY VARY DEPENDING ON LIFT STATION SIZE AND ACTUAL SITE CONFIGURATION.
 2. REFER TO CITY OF BONNEY LAKE PUBLIC WORKS DESIGN STANDARDS SECTION 515 - "SANITARY SEWER STANDARDS" FOR ADDITIONAL REQUIREMENTS NOT SHOWN.
 3. SEE STANDARD DETAIL SS19 FOR CONTROL BUILDING AND UNDERGROUND PIPING LAYOUT.
 4. ALL ACCESS HATCHES IN ASPHALT SURFACING SHALL BE AT GRADE WITH SURFACE RUN OFF AWAY FROM HATCH. ALL ACCESS HATCHES SHALL BE SUITABLE FOR H-20 WHEEL LOADING.
 5. WATER SERVICE PIPING SHALL PER CITY OF BONNEY LAKE PUBLIC WORKS DESIGN STANDARDS SECTION 400 - "WATER SYSTEM STANDARDS".
 6. ALL IMPERVIOUS SURFACES SHALL BE SLOPED TO DRAIN AWAY FROM EQUIPMENT, BUILDING, VAULTS AND WET WELL.
 7. PROPERTY LINE SETBACKS NOT SHOWN. SEE ZONING REQUIREMENTS.
 8. STORMWATER MITIGATION NOT SHOWN.

CONCEPTUAL LIFT STATION
SITE PLAN
NO SCALE

Approved: *[Signature]* March 16, 2018
 City Engineer Date
 SANITARY SEWER STANDARD DETAIL



Dwg No: **SS18**
CONCEPTUAL LIFT STATION SITE PLAN