



NOTES:

1. NO DEFLECTION SHALL BE ALLOWED AT EITHER COUPLING.
2. CUT-IN CONNECTIONS ON STEEL PIPE TO USE DIXOD STEEL TRANSITION COUPLINGS ROMAC OR EQUAL.
3. IN-LINE VALVE(S) IN EXISTING SYSTEM MAY BE REQUIRED AT THE SOLE DISCRETION OF THE CITY. (NOTE: VALVE(S) ARE NOT SHOWN ABOVE FOR CLARITY)
4. DUCTILE IRON LONG PATTERN SLEEVE IS REQUIRED WHEN CONNECTING TO CAST IRON, PVC, OR DUCTILE IRON PIPE. A ROMAC 501 COUPLING IS REQUIRED FOR CONNECTIONS TO ASBESTOS CONCRETE OR STEEL PIPE.

Approved:  March 16, 2018
 City Engineer Date



Dwg No: **W7**
CUT IN CONNECTION

WATER STANDARD DETAIL