



**NOTES:**

1. STANDING SIDE SEWERS ONLY ALLOWED IN CASES WHERE THE DEPTH OF THE MAIN EXCEEDS 25- FEET.
2. SEE TYPICAL TRENCH SECTION FOR DUCTILE IRON SEWER PIPE.
3. LOCATION OF STANDING SIDE SEWERS MUST BE APPROVED BY CITY PRIOR TO INSTALLATION.

Approved:  June 17, 2005  
 City Engineer Date  
**SANITARY SEWER STANDARD DETAIL**



Dwg No: **SS11**  
**STANDING SIDE SEWER**