


NOTES:

1. TRENCH SHALL BE BACKFILLED AND COMPACTED IN ACCORDANCE WITH WSDOT 7-08.3(3).
2. BEDDING MATERIAL SHALL BE PEA GRAVEL OR APPROVED EQUAL. PIPE ZONE BACKFILL SHALL BE PEA GRAVEL (OR APPROVED EQUAL) TO THE SPRING LINE FOR DUCTILE IRON PIPE AND TO A DEPTH OF 6" ABOVE THE CROWN FOR PVC PIPE AS SHOWN ABOVE.
3. FOR EXISTING ROADS, BACKFILL MATERIAL ABOVE THE PIPE ZONE SHALL BE 1½" CRUSHED ROCK. FOR NEW ROAD CONSTRUCTION, BACKFILL MATERIAL ABOVE THE PIPE ZONE SHALL BE GRAVEL BORROW OR SELECT BORROW IN ACCORDANCE WITH WSDOT 9-03.14 OR 1½" CRUSHED ROCK OR AS APPROVED IN WRITING BY THE CITY ENGINEER.

1	Added Note 3.	8/3/11
Rev No.	Revisions	Date
Approved:		June 17, 2005
City Engineer		Date
SANITARY SEWER STANDARD DETAIL		



Dwg No: **SS7**  
**SANITARY SEWER TRENCH SECTION**