



NOTES:

1. TRENCH SHALL BE BACKFILLED AND COMPACTED IN ACCORDANCE WITH WSDOT 7-09.3(10) & (11) OR AS APPROVED IN WRITING BY THE CITY ENGINEER.
2. BEDDING (IF REQUIRED BY THE CITY), SHALL CONFORM TO WSDOT 7-09.3(9).
3. BACKFILL MATERIAL SHALL BE GRAVEL BORROW OR SELECT BORROW IN ACCORDANCE WITH WSDOT 9-03.14 OR 1 1/4" CRUSHED ROCK OR AS APPROVED IN WRITING BY THE CITY ENGINEER.

Approved:  June 17, 2015
 City Engineer Date



Dwg No:

W2

WATER STANDARD DETAIL

**WATER MAIN
TRENCH SECTION**