



REDUCED PRESSURE BACKFLOW DEVICE
NOT TO SCALE

- ① PROVIDE CITY APPROVED SUPPORT FOR 2 1/2" AND LARGER DEVICES.
- ② DRAIN TO BE SIZED AS PER DOH REQUIREMENTS

Approved:  June 17, 2015
 City Engineer Date
WATER STANDARD DETAIL



Dwg No: **W20**
REDUCED PRESSURE BACKFLOW DEVICE